



Government of Jammu and Kashmir
Power Development Department
Civil Secretariat, Jammu


Subject:- Additional 363.46 KVA Power Load Connection aggregating total load upto 2215.61 KVA in favour of M/S Emcure Pharmaceuticals Ltd. Sidco Industries, Bari Brahman, Jammu.

Reference:-Letter No.DC/PC/TO-II/156/342-43 dated 04.07.2014 from Development Commissioner (Power).

Government Order No. 70 -PDD of 2015
Dated: 09.04.2015

Sanction is hereby accorded to the grant of additional 363.46 KVA Power Load Connection aggregating total load upto 2215.61 KVA in favour of M/S Emcure Pharmaceuticals Ltd. Sidco Industries, Bari Brahman, Jammu subject to the following conditions:-

- i. The applied load is proposed to be accommodated from 132/33kv, 2x50MVA, R/Stn. Phase-II, Bari Brahmana through 33 kv outgoing feeder BB-II on the existing 2.5MVA S/Stn. of consumer.
- ii. Any addition, alteration, creation etc. of the electrical infrastructure necessitated in order to feed power to the consumer shall be at the cost of the consumer.
- iii. The construction of electrical power supply infrastructure at sites shall be strictly as per the "General Technical Guidelines for Infrastructure at Industrial & Commercial sites issued by DCP in August, 2009."
- iv. The procurement/purchase of Trivector energy meter shall be the responsibility of consumer. The meter shall be DLMS complaint and shall be of ABB, Secure or L&T make and have provision for record of load survey data and time of day (T.O.D) tariff facility also along with CT/PT unit at the S/Stn for metering on 33KV side as per the specification to be provided by the Chief Engineer, EM&RE Wing, Jammu and the connection



8/4/15

- shall not be physically released until the meter is installed and sealed by the Department.
- v. The location of HT metering unit shall be within, but close to entrance point of the consumer premises so that departmental inspectors can approach the location without having need to avail the assistance of the personnel of the consumer. The location shall be visible from outside. HT metering unit including CT/PT unit and the meter shall be mounted on double pole structure.
 - vi. The metering equipment will be inspected, tested and sealed by the inter wing teams comprising of representatives from TTIC Wing, Commercial and Survey Wing and EM & RE Wing.
 - vii. The consumer shall liquidate all up to date electricity dues at the first instance.
 - viii. The Physical Connection shall be released only after installation of Capacitor bank of adequate capacity (Automatically Switched) at the cost of consumer.
 - ix. The Consumer shall produce valid NOC from J&K Pollution Control Board.
 - x. The consumer shall produce NOC from Inspection Agency of the Department.
 - xi. The consumer shall abide by all rules and regulations as per electricity Act/rules and tariff.
 - xii. The physical connection to the unit shall be released only after the Superintending Engineer concerned physically checks that the metering and all above guidelines have been implemented at site and issues a certificate of fulfillment of all requirements in this regard.
 - xiii. The sanction shall be liable to cancellation if the unit is found in theft of Power/Energy.
 - xiv. The power sanction to the unit may be released after the 50MVA transformer (presently out of circuit due to 132 KV bushing replacement) is again put into circuit.
 - xv. Fulfillment of other conditions issued from time to time.

By order of the Government of Jammu and Kashmir.

Sd/-
(Sundeep K. Nayak) IAS
Principal Secretary to Government
Power Development Department
Dated: 09.04.2015

No. PDD/IV/31/2009


Sundeep K. Nayak
09/04/2015

Copy to the:-

1. Principal Secretary to Hon'ble Chief Minister
2. Development Commissioner (Power), J&K, Jammu.
3. Private Secretary to Hon'ble Deputy Chief Minister.
4. Private Secretary to Hon'ble Minister of State for Power
5. Private Secretary to Principal Secretary to Government, Power Development Department
- ✓ 6. Nodal Officer (Website), PDD (Technical Director, NIC)
7. Government Order file (w.3.s.c) shukhinder
8. Stock file.

Tahir Ajaz
(Tahir Ajaz) 8/4/2015

Deputy Secretary to Government,
Power Development Department

dl
8/4/15